



产品认证证书

证书编号: CQC12001084355

申请人名称及地址

厦门赛尔特电子有限公司
厦门火炬高新区(翔安)产业区翔安西路8067号

制造商名称及地址

厦门赛尔特电子有限公司
厦门火炬高新区(翔安)产业区翔安西路8067号

生产企业名称及地址

厦门赛尔特电子有限公司 (V013237)
厦门火炬高新区(翔安)产业区翔安西路8067号

产品名称和系列、规格、型号

金属氧化物压敏电阻器

MOV20D (201K~122K)、SFV20D (201K~122K) 压敏电压: 200V~1200V; 最大连续交流电压: 130VAC~750VAC, 压敏电压的允许偏差为K: $\pm 10\%$; 气候类别为40/085/21[型号为MOV20D (220K~181K)、SFV20D (220K~181K) 的压敏电阻器仅适用于GB/T10193-1997, GB/T10194-1997]。具体规格型号详见附件

产品标准和技术要求

GB/T10193-1997; GB/T10194-1997; GB4943.1-2011; GB8898-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-471551-2012认证规则的要求, 特发此证。

发证日期: 2013年04月09日 有效期至: 2017年04月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年11月22日

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0043642



PRODUCT CERTIFICATE

No.: CQC12001084355

NAME AND ADDRESS OF THE APPLICANT

Xiamen Set Electronics Co., Ltd.
No.8067 Xiang'an Xi Road, Xiamen Torch High-tech Industrial Development Zone, Xiang'an Industry District, Xiamen, China

NAME AND ADDRESS OF THE MANUFACTURER

Xiamen Set Electronics Co., Ltd.
No.8067 Xiang'an Xi Road, Xiamen Torch High-tech Industrial Development Zone, Xiang'an Industry District, Xiamen, China

NAME AND ADDRESS OF THE FACTORY

Xiamen Set Electronics Co., Ltd. (V013237)
No.8067 Xiang'an Xi Road, Xiamen Torch High-tech Industrial Development Zone, Xiang'an Industry District, Xiamen, China

NAME, MODEL AND SPECIFICATION

Metal Oxide Varistor

MOV20D (201K~122K)、SFV20D (201K~122K) 压敏电压: 200V~1200V; 最大连续交流电压: 130VAC~750VAC, 压敏电压的允许偏差为K: $\pm 10\%$; 气候类别为40/085/21[型号为MOV20D (220K~181K)、SFV20D (220K~181K) 的压敏电阻器仅适用于GB/T10193-1997, GB/T10194-1997]。具体规格型号详见附件

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T10193-1997; GB/T10194-1997; GB4943.1-2011; GB8898-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC11-471551-2012.

Date of issue: Apr.09,2013

Date of expiry: Apr.09,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov.22,2012

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0043642



产品认证证书

附录:

第 1 页 共 2 页

证书编号: CQC12001084355

纸号: 43642

型号规格		压敏电压 (V)	最大连续交流电压 $A \cdot C_{r.m.s}$ (V)	标准
MOV20D220K	SFV20D220K	22	14	GB/T10193-1997, GB/T10194-1997
MOV20D270K	SFV20D270K	27	17	
MOV20D330K	SFV20D330K	33	20	
MOV20D390K	SFV20D390K	39	25	
MOV20D470K	SFV20D470K	47	30	
MOV20D560K	SFV20D560K	56	35	
MOV20D680K	SFV20D680K	68	40	
MOV20D820K	SFV20D820K	82	50	
MOV20D101K	SFV20D101K	100	60	
MOV20D121K	SFV20D121K	120	75	
MOV20D151K	SFV20D151K	150	95	
MOV20D181K	SFV20D181K	180	115	GB/T10193-1997, GB/T10194-1997, GB4943.1-2011, GB8898-2011
MOV20D201K	SFV20D201K	200	130	
MOV20D221K	SFV20D221K	220	140	
MOV20D241K	SFV20D241K	240	150	
MOV20D271K	SFV20D271K	270	175	
MOV20D301K	SFV20D301K	300	190	
MOV20D331K	SFV20D331K	330	210	
MOV20D361K	SFV20D361K	360	230	

注: 此附录与证书同时使用时有效。

主任: 



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



产品认证证书

附录:

第 2 页 共 2 页

证书编号: CQC12001084355

纸号: 43642

MOV20D391K	SFV20D391K	390	250
MOV20D431K	SFV20D431K	430	275
MOV20D471K	SFV20D471K	470	300
MOV20D511K	SFV20D511K	510	320
MOV20D561K	SFV20D561K	560	350
MOV20D621K	SFV20D621K	620	385
MOV20D681K	SFV20D681K	680	420
MOV20D751K	SFV20D751K	750	460
MOV20D781K	SFV20D781K	780	485
MOV20D821K	SFV20D821K	820	510
MOV20D911K	SFV20D911K	910	550
MOV20D951K	SFV20D951K	950	575
MOV20D102K	SFV20D102K	1000	625
MOV20D112K	SFV20D112K	1100	680
MOV20D122K	SFV20D122K	1200	750

注: 此附录与证书同时使用时有效。

主任:



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>