

# Agency Information

The certificate is only used for browsing on the web and proves that SETsafe | SETfuse has been certified.

If you need a FULL-VERSION certificate, please contact us: [sales@SETfuse.com](mailto:sales@SETfuse.com)

该证书只用于在网页浏览，证明SETsafe | SETfuse已获得认证，如需要完整版本证书，请联系我们: [sales@SETfuse.com](mailto:sales@SETfuse.com)

# Zertifikat

mit überwachter Konformität

# Certificate

of surveyed conformity



Zertifikat Nr. *Certificate No.*  
J 50497919

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

*Date of Issue*

05-ZHANGVIVI-CN21UQHI 001 31.03.2021 (day/mo/yr)

**Genehmigungsinhaber *License Holder***

Xiamen Set Electronics Co., Ltd.  
No.8067, Xiangan Xi Road, Xiamen  
Torch High-Tech Industrial Develop-  
ment Zone, Xiangan Industry District  
Xiamen  
Fujian  
P.R. China

**Fertigungsstätte *Manufacturing Plant***

Xiamen Set Electronics Co., Ltd.  
No.8001, Xiangan Xi Road,  
Xiamen Torch High-Tech  
Industrial Development Zone,  
Xiangan Industry District, Xiamen,  
Fujian  
P.R. China

**Prüfzeichen *Test Mark***



Safety  
Regular  
Production  
Surveillance

www.tuv.com  
ID 1111237480

**Geprüft nach *Tested acc. to***

EN 61643-31:2019

**Zertifiziertes Produkt (Geräteidentifikation)**

*Certified Product (Product Identification)*

**Lizenzentgelte - Einheit**

*License Fee - Unit*

(TMOV for PV system)

Type Designation: TFMOV20Mxxx (xxx=385 to 750)  
Details See Appendix 1

7

Trademark : SET  
Ucpv : DC 500V to 1000V  
In : 20 kA  
Imax : 40 kA  
Up : 1.8kV to 3.3kV  
Iscpv : 1000 A  
Type of SPD : Type 2  
Number of ports : one port  
Temp./Humidity : -40°C to +85°C/5%RH to 95%RH  
Altitude : -500m to 5000m

Remark: The labelling requirements acc. to EU Directive  
2001/95 have to be observed for distribution within the EEA.

7

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.  
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.  
This certificate is based on our Testing and Certification Regulation. The product  
fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

