

Agency Information

This certificate is only used for web browsing, proving that the SETsafe | SETfuse product has been certified.

For the full version, please contact: sales@SETfuse.com

Thank you for your support.

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50718141 0001

Berichtsnummer Report No.:

CN25T93M 001

Produkt Product:

Fuse Link

(Low-voltage Fuses for the protection of batteries and battery systems)

Modell Type:
Bezeichnung Designation:

LFR15NA-xA-y

x = 32, 40, 50, 63, 80, 100, 125, 150, 160, 180, 200, 250, 300, 315,
350 or 400

y = BT, when x = 32 to 400

y = PT2, when x = 32 to 160

Trademark

: SET SETsafe SETfuse

Rated Voltage

: (1)DC 250V (2)DC 150V

Rated Current (In)

: (1)32A, 40A, 50A, 63A, 80A, 100A, 125A,
150A, 160A, 180A, 200A, 250A
(2)300A, 315A, 350A, 400A

Rated Breaking Capacity : 50kA

Minimum breaking capacity : 3In

Rated Power Dissipation : See appendix 1

Dimension or Size : See appendix 1

Arc Voltage Limits : 500V (peak value)

Breaking range and Utilization category : aBat

ANLAGE (Appendix): 1

